1	Tidal Range Electricity Generation into the 22 nd Century.
2	David Vandercruyssen ^a , Simon Baker ^a , David Howard ^b & George Aggidis ^{a*}
3 4	a Lancaster University Renewable Energy Group, School of Engineering, Bailrigg, Lancaster, LA1 4YR, UK.
5 6	b UK Centre for Ecology & Hydrology, Maclean Building, Benson Lane, Crowmarsh Gifford, Wallingford, Oxfordshire, OX10 8BB
7 8	*Corresponding author d.vandercruyssen@lancaster.ac.uk
9	Author 1
10	David Vandercruyssen, PhD, CEng, FICE, FIStructE, MCIHT
11	Research student at Lancaster University School of Engineering, Renewable Energy and Fluid
12	Machinery Group,
13	 ORCID number_0000-0002-3474-3406
14	• Performed analysis, processed data, generated figures and tables, and authored the paper.
15	
16	Author 2
17	Simon Baker, MRes
18	Research student at Lancaster University School of Engineering, Renewable Energy and Fluid
19	Machinery Group,
20	• Wrote the code for the 0-D model and assisted with the analysis and text.
21	
22	Author 3
23	David Howard, PhD, PGCE, MBES, MIALE, FRES,
24	UK Centre for Ecology & Hydrology, Lancaster Environment Centre,
25	• ORCID number_0000-0003-4494-7450
26	• Environmental input, text editing, proof reading and suggestions on improving clarity of formulae
27	and tables.
28	
29	Author 4
30	• Prof George Aggidis, PhD, Eur Ing, CEng, CMarEng, MASME, FIMarEST, FEI, FIET, FIMechE

• Head of Energy, Lancaster University School of Engineering, Renewable Energy and Fluid

32 Machinery Group,

- 33 ORCID number 0000-0002-5175-4529
- Overall direction of the research and themes, approval of the paper.
- 35

36 Abstract

37 Tidal range electricity generation schemes are designed to have a minimum operational life of at least 38 120 years, making it important to plan for changes such as Sea Level Rise (SLR). Previous studies have 39 shown that schemes can maintain the existing tidal range within the impoundment and protect areas 40 from flooding. Here it is demonstrated that tidal range technology can maintain the current tidal 41 extent despite SLR and suggests the operational strategies to achieve it. The approach is the only way 42 to safeguard existing intertidal habitats. Mechanical and electrical plant requires a major overall, 43 upgrade or replacement every 40 years; the levelised cost of energy (LCOE) is structured in 40year 44 periods reducing after the first period. Increasing the capacity or efficiency of the plant during the 45 refits allows the protection of low-lying areas to be maintained and more electricity to be generated. 46 The strategy requires energy to be used in pumping to achieve the current low tidal limits and the 47 incoming tide to be curtailed to maintain the high tide extent, but there is very little effect on annual 48 electricity production (AEP). Flexible operation can offer some protection from riverine flooding and 49 existing inundation cycles can be maintained.

50

51 <u>Highlights</u>

- Changes to tidal range electricity generation with increasing sea level.
- Ability to protect intertidal areas and habitats by maintaining existing tide limits.
- Two-way tidal range generation with pumping to existing low tide limits.

55

56 <u>Key words</u>

57 Renewable Energy, Tidal Range Power, Sea level rise, protecting intertidal habitats.

58

59 **1 INTRODUCTION**

60 Previous papers by the authors have described specific aspects of tidal range power generation in 61 Great Britain. Their first paper compared case studies of a coastal lagoon and an estuarine barrage 62 (Vandercruyssen et al., 2022a). The paper used the Lancaster 0-D tidal range model to estimate the 63 annual electricity production (AEP) for various combinations of turbine numbers, generator ratings 64 and sluice ratios. The second paper developed a cost model for tidal range schemes that can be used 65 for initial estimates of capital costs, so that schemes can be ranked in order of financial returns 66 (Vandercruyssen et al., 2022b). The cost model requires limited site-specific information and is 67 intended for pre-feasibility estimates only. The third paper combines the first and second to show 68 how the components of schemes can be optimised to find the lowest cost of energy (Vandercruyssen 69 D et al., 2023). Funding mechanisms were discussed, and tidal range was shown as sufficiently

economic for feasibility studies to commence in earnest. Here the consequences of sea level rise (SLR)are investigated.

The most obvious consideration for such long-term tidal range projects is the impact of climate change on mean sea level. SLR is already a reality (Intergovernmental Panel on Climate Change (IPCC), 2014). The Lancaster 0-D model allows the user to specify a value for SLR and all values in the tidal cycle are then increased by this level. The tidal range may also be factored to increase or decrease. Thus, SLR can be modelled, and its effects simulated.

A barrage, if designed and operated appropriately, can mitigate the impacts of SLR on the intertidal zone and can help satisfy the Government's legal commitment to protect valuable designated ecosystems. If the ecological and environmental considerations dictate that the tidal range within the barrage must be maintained at pre-SLR levels, then the design and/or the annual electricity production (AEP) may be compromised. Similarly, a barrage can be used to reduce terrestrial flooding by allowing free drainage into the impoundment.

83

84 2 Sea level rise

The predictions over the next 120 years vary widely due to uncertainties in future net greenhouse gas emissions, and the environmental mechanisms involved. The IMechE (Inst of Mech Engs, 2019) looking 80 years ahead recommended coastal developers to "... prepare for a minimum of 1 m rise in sea level this century but plan for 3 meters of rise".

89 As water warms and expands, and ice sheets melt there will be an increased volume of water in the 90 seas it is possible that tidal range and storm surges will also increase. Pickering et al (Pickering et al., 91 2012) used the Dutch Continental Shelf Model to estimate the effects of a 2 m rise in global average 92 sea levels on the tidal range. They concluded there would be little effect on range (i.e., the difference 93 in height between high and low water) in the North Wales to Liverpool Bay area. Surprisingly, the 94 altered intertidal morphology suggests that the amplitude of the tidal range around the Severn Estuary 95 would fall to 91% of the current range. Khojasteh (Danial Khojasteh et al., 2022) describe the effects 96 of SLR on estuaries. In the absence of more reliable estimates of this, the authors assume that the 97 amplitudes of the tidal range remain constant. Without a barrage, much of the low-level intertidal 98 areas in estuaries will be inundated with significant loss to the environment. Existing sea defences 99 will prevent tidal encroachment inland, so the intertidal area will shrink.

There are upwards of 75 km² of low-lying land surrounding Morecambe Bay that are protected by approximately 50 km length of embankments plus one-way river flow gates and pumping stations. SLR threatens this infrastructure; embankments will need to be raised to prevent future breaches. Ultimately, the questions of cost of construction, the operational performance and multiple benefits must be answered by the UK Government. When generation is suspended or reduced to prevent flooding, the cost of deviating from maximum energy generation needs to be offset in the valuation.

Climate change is also predicted to increase the likelihood and severity of storms, whilst they become less predictable (Intergovernmental Panel on Climate Change (IPCC), 2014). The main catastrophic flood risk in the catchments surrounding Morecambe Bay at present is from rivers following heavy rain (Environment Agency and Cumbria County Council, 2017). The ability to drain the land is impeded by high tides and will become increasingly difficult with SLR. The benefits of a tidal barrage for flood protection was discussed in (Vandercruyssen et al., 2022a).

113 **3 Pumping**

114 Pumping is the forced movement of water into or out of the impoundment against the existing 115 direction of flow or stasis. It can increase the head before generation starts and is reported to increase 116 the nett AEP by 10% (Yates et al., 2013). The operation usually employs the turbines as pumps against 117 low heads, after slack tide, to increase the head available during the next generation sequence. 118 However, it needs to be clear what is meant by pumping, as there are several modes of operation. For 119 2-way generation without pumping, the range of water levels inside the impoundment, or lagoon, is 120 less than the natural tide range over the same period. The equalisation of water levels occurs just 121 after high or low tide. The following pumping scenarios are considered:-

122 <u>Cycle-by-cycle</u>

The cycle by cycle (C-by-C) pumping scenario is used to maximise nett power generation by pumping to try to match the natual tide level for each cycle. After generation the slucies are opened to equalise levels as quickly as possible. The equilisation times for high and low tides inside the impoundment will be slightly behind the natural tide extreams. The pumps then attempt to bring the impounded water level to the previous natural tide limit. There is no guarantee that the natural tide levels are reached for all tides as there may not be sufficient time to achieve the goal.

129 Forced limits

130 The Forced limits (FL) mode checks that the natural tide levels are matched. If not, then the sluices 131 are openned early to allow sufficient time for the natural tide extremes to be met for each tide. There 132 will be more power used in pumping compared to the C-by-C mode.

133 Pump storeage/economic pumping

134 Another possible scenario is to pump to the maximum pumping head or mean spring tide levels. 135 Exceptionally, in periods of high demand and low supply (eg. no wind) it would be possible to pump 136 to highest or lowest astronomical tide level. Effectively providing a small component of pumped 137 storage capacity. This is constrainted to specific times when energy can be captured and when it must 138 be used within the next phase of the cycle. The stored head is low (say max 3 m) but with a surface 139 area of 150 to 300 km², the potential is not insignificant. It would only be economic when the price of 140 electricity for pumping is say 50 - 60% of the price at the next generation cycle, typically 2- or 3-hours 141 later; either early morning or afternoon before the morning and evening peak periods. This requires 142 estimating the price of electricity 3-hours ahead rather than the 24-hours forward pricing used for 143 most of the grid price bidding process. There is no point in pumping at 6 pm to get a lower price in 144 the late evening or overnight. The approach is described by Harcourt (Harcourt et al., 2019), who 145 suggested a 23% improvement of financial return is possible for Swansea Bay.

146

147 Maintaining pre-SLR levels

148 It is possible to maintain existing sea levels within the impoundment provided there is sufficient 149 pumping capacity. At the end of generation on an ebb tide the pumps are used to lower the 150 impounded water to the desired low tide levels. On the flood tide the turbines and sluice gates are 151 closed when the impounded water level reaches the target for high tide; or earlier if a storm is 152 expected. The adjusted operation changes the balance between the ebb and flood generation 153 potential. There will still be a good head at the end of generation on the flood tide. Conversely there 154 will be more pumping energy used on the ebb tide. This effect may be more pronounced on coastal lagoons than estuaries which have much smaller wetted area at low tides (Vandercruyssen et al.,2022a).

157

158 Pump performance

159 For commercial reasons there is very little published information on performance of hydraulic turbines 160 used as pumps. The principal is well established as demonstrated by the Dinorwig Pumped Storage 161 scheme (Baines et al., 1983). The scheme uses six 300 MW reversible pump/turbines that can pump 162 to approximately 500m head. Water is pumped at night for discharge the following day. For tidal 163 range in the UK the maximum pumping head would be 3 or 4 m. The pump performance used in the 164 Lancaster 0-D is based on information from the La Rance scheme in France, where the turbines in 165 pump mode are operated at a quarter of the rated generating power (Baker, 2021). The pump 166 operates at a user specified constant power with a linear relationship between head, flow and 167 efficiency. Baker (Baker, 2021; Baker et al., 2023) showed that a turbine of 8 m diameter and 7.5 MW pumping power, for example, the flow rate starts at 380 m³s⁻¹ at zero head and drops to 240 m³s⁻¹ at 168 169 a maximum head of 2.3 m. Higher flow rates and maximum head can be achieved with higher power 170 at the expense of efficiency: the same turbine at 25 MW can pump 480 m³s⁻¹ at a head of 2.3 m, and 171 can pump up to a head of 5.2 m. For this paper, pumping power has been limited to 7.5 MW.

172

173 **4 0-D Model**

174 The 0-D model estimates power generation by simply using the volume of water moving with no 175 consideration of the morphology of the impoundment; it assumes that the water inside the 176 impoundment is always uniformly level. The approach is ideal for initial assessments for scheme 177 development and component sizing. More complex models can be used when specific site data are 178 available but are far more time consuming to perform. The mathematics of the 0-D model has been 179 described by Aggidis (Aggidis and Benzon, 2013; Aggidis and Feather, 2012) who provides the 180 equations underpinning the model and the hydraulic characteristics of the turbine. A Hill chart 181 describes efficiency and output under different discharge and flow conditions; in the Lancaster model 182 the characteristics of an Andritz 3-blade, bulb turbines was incorporated. The Hill chart is based on 183 the performance of model tests. The equations relate the model to full size machine operation.

184 To demonstrate the effects of SLR the authors continue with the two contrasting development 185 schemes used in their previous paper (Vandercruyssen et al., 2022a). For estuarine schemes, such as 186 Morecambe Bay (MB), there are multiple overlapping environmental and ecological designations, 187 aimed at protecting the whole ecosystem, specific components, and their ecosystem services. In 188 addition, there are specific areas allocated to shell fishing, a long-standing traditional industry. 189 Saltmarsh acts as an important carbon sink and should be protected where possible (Laffoley, 2022). 190 A coastal lagoon, such as North Wales, does not have the diversity of habitats and protected areas as 191 an estuary and are currently considered easier to gain approval for development.

The presence of a barrage will change the nature of the intertidal zone that it impounds, but it is also an environmental management scheme that can safeguard and operate for the benefit of the ecosystem. Importantly, it can limit the height of the high tides to alleviate tidal flooding, mitigate riverine flooding and maintain the current tidal range, thus preserving existing habitats. The criterion of maintaining the current tidal range has been applied as part of the study as a proxy for an environmental requirement. The Lancaster 0-D model allows the user to specify a value for SLR and apumping option to match pre-SLR levels.

199

200 4.1 Assumptions

It is assumed that each site starts with the base configuration of the minimum LCOE describedpreviously (Vandercruyssen D et al., 2023).

- The Morecambe Bay estuarine barrage (MB) will use 8 m diameter turbines with 20 MW
 generators and a sluice ration of 2.
- The North Wales coastal lagoon (NW) will use 8 m diameter turbines with 15 MW generators
 and a sluice ration of 2.
- In both cases, pumping power is limited to 7.5 MW using turbines as pumps.
- The tidal range does not change with SLR.

It is assumed that each scheme will have a minimum design life of 120 years and that major
refurbishment or replants will occur every 40 years, phased over +/- 5 years.

The IMechE's prediction of 1.0 m rise in average sea levels by the end of the century, equates to a 0.5
m rise every 40 years. The approach is indicative for initial planning; more accurate figures will
develop over time.

214

5 Morecambe Bay Estuarine Barrage

216 In Britain, estuaries commonly contain important habitats and consequently have more designations 217 and protected areas (e.g. SSSI, AONB, RAMSAR, RSPB) than other locations. Morecambe Bay has more 218 than most, see Table 3 published in (Vandercruyssen et al., 2022a) for a detailed list and glossary. The 219 strength of formal protection has been a major issue that has deterred the development of tidal range 220 barrages across estuaries. There is a commonly held misconception that low lying intertidal habitats 221 will remain flooded within a tidal barrage. This perception was reiterated as recently as 2008 in the 222 Government backed study of the proposals for the Severn Estuary (DECC et al., 2008). Contrary to 223 these ideas, the analysis presented here demonstrates that 2-way generation and pumping is the only 224 way to protect sensitive areas from SLR whilst maintaining the dynamic tidal cycles.

With current average sea levels, the surface, or wetted, area of the impounded water is approximately the same for NW and MB at approximately 150 km². The wetted area of MB at mean low water springs (MLWS) is 50% of that for NW (Vandercruyssen et al., 2022a). With a 2 m SLR the wetted area of MB is still less that of NW. Therefore, the pumping effort needed to maintain existing low water levels should be less for an estuary.

The Lancaster 0-D model has been used to calculate the AEP expected from the estuary under various
 combinations of turbine and sluice numbers and pumping modes for SLR up to 2 m.

232

Table 1 Annual electricity produced in the Morcambe Bay Esturine Barrage with 8 m diameter turbines and 20 MW generators
 under various levels of SLR and numbers of turbines.

More	cambe Ba	ay Barra	ge	Annual Electricty Produced (TWh)											
Pumping	Number of turbines	Sluices 15x15 m		Sea level rise (m)											
Mode		Ratio	No.	0.0	0.2	0.4	0.6	0.8	1.0	1.2	1.4	1.6	1.8	2.0	
	120	2.0	54	5.39	5.43	5.45	5.46	5.46	5.47	5.47	5.45	5.42	5.35	5.27	
C-by-C	140	2.0	63	6.12	6.18	6.22	6.25	6.27	6.26	6.24	6.19	6.14	6.07	5.97	
	160	2.0	71	6.69	6.75	6.79	6.83	6.82	6.82	6.74	6.72	6.64	6.53	6.45	
Forcod	120	2.0	54	5.26	5.34	5.41	5.43	5.41	5.36	5.26	5.07	4.81			
Limite	140	2.0	63	6.15	6.21	6.24	6.27	6.28	6.27	6.20	6.08	5.88	5.65		
LITTILS	160	2.0	71	6.72	6.77	6.80	6.83	6.86	6.84	6.81	6.73	6.58	6.41		

236

Table 1 shows the estimated AEP for 60 combinations of SLR, turbine and sluice numbers, and pumping regimes. The analysis demonstrates the power and flexibility of 0-D modelling; it would be extremely time consuming using 2- or 3-D models. The blank cells for the FL mode show where the current model struggles to match the required minimum tide levels and the results are unreliable.

Figure 1 shows the data of Table 1 in graphical form. The initial configuration, using 8.0 m diameter bulb turbines with 20 MW generators, and a sluice ratio of 2, was the optimum configuration suggested by (Vandercruyssen D et al., 2023). Other configurations employing 140 and 160 turbines were also considered previously and are used to show the consequences of increasing the number of turbines in line with SLR. The 8 m diameter bulb turbine is considered the largest, and most efficient, currently available.





Figure 1 Annual electricity produced in the Morecambe Bay estuarine barrage under various levels of SLR and plant
 configurations.

In Figure 1 solid lines represent the C-by-C pumping mode that maximises the power generated, whilst dashed lines represent the FL pumping mode. The separation between the solid and dashed lines shows the AEP loss due to maintaining pre-SLR tide levels, i.e., the cost of fully mitigating SLR. In all cases (turbine numbers and SLR) the FL maintains the tides at their current cycle levels protecting the habitats until SLR reaches 0.8 m. It is to be expected that once SLR exceeds 1.0 m, other measures will need to be taken.

For SLR up to 0.6 m or 0.8 m, all scenarios (C-by-C and FL) demonstrate a slight increase in AEP. For the base case of 120 turbo-generators it is apparent there is significant and increasing cost to maintain existing sea levels when SLR exceeds 1.1 m. The larger installations of 140 and 160 turbines fare much better in meeting SLR up to 1.4 m. Thus, the proposed base case for MB should include at least 140 x 8 m diameter turbines. Above 1.8 m of SLR the performance drops dramatically. It shows the necessity of designing for the future, either during the initial build or providing an easy means to expand later.

264 To understand this rather complex graph it is necessary to examine the tide and impoundment levels 265 in detail. Figure 2 a shows the water levels for a 12-day period of tides with 1.4 m of SLR. The blue 266 lines are the sea levels the red lines are the impoundment levels with the C-by-C pumping mode. 267 The green dashed lines are the impoundment levels with the FL pumping mode. The existing high 268 tide levels are easily maintained by stopping generation and closing sluices when the desired levels 269 are met. The flat hold periods at neap tides are longer than those at spring tide. For the neap tide 270 the C-by-C mode fails to reach the lower existing limit by about 0.5 m. The FL mode starts its ebb 271 generation slightly earlier and runs at a faster flow to reach the pre-SLR low water levels. For the 272 spring tides the C-by-C mode is about 0.9 m short of the desired low tide levels so more pumping is 273 required. The FL mode achieves the required current low levels with an additional loss of only 2% of 274 the AEP. Spring low tide inside the impoundment lags the natural tide by 2-hours 36-minutes for C-275 by-C and 2-hours 0-minutes for FL modes.



279 <u>Figure 2</u> Morecambe Bay estuarine barrage using 140 x 8 m x 20 MW, 1.4 m sea level rise.

281 6 North Wales Coastal Lagoon

The surface area of the impounded water at low tide for a coastal lagoon, such as this case study site, is a higher proportion of the area at mean tide than a typical estuary. This means the flood generation mode is more significant than for a similar sized estuary. Consequently, the coastal lagoon will require more pumping effort to reach existing low water levels and maintain them against SLR. However, there are no environmental designated areas withing this proposed scheme. Thus, it could be argued that maintaining existing low water levels is less important compared to estuaries. However, protection is still possible.

The Lancaster 0-D model has been used to calculate the AEP expected from the lagoon under various
 combinations or turbine and sluice numbers and pumping modes for SLR up to 2 metres, see Table 2
 and Figure 3.

292

Table 2 Annual electricity produced in the North Wales Coastal Lagoon with 8 m diameter turbines and 15 MW generators
 under various levels of SLR and plant configurations.

North V	Vales Coa	Annual Electricty Produced (TWh)													
Pumping	Number of turbines	Sluices 15x15 m		Sea level rise (m)											
Mode		Ratio	No.	0.0	0.2	0.4	0.6	0.8	1.0	1.2	1.4	1.6	1.8	2.0	
	125	2	56	4.37	4.39	4.39	4.34	4.28	4.22	4.12	4.00	3.89	3.76	3.59	
C-by-C	140	2	63	4.68	4.72	4.71	4.68	4.61	4.53	4.42	4.29	4.15	4.00	3.85	
	160	2	72	5.00	5.03	5.01	4.97	4.91	4.83	4.73	4.59	4.44	4.29	4.14	
Forcod	125	2	56	4.33	4.36	4.36	4.32	4.25	4.16	4.05	3.85	3.56			
Limite	140	2	63	4.68	4.72	4.70	4.64	4.57	4.53	4.40	4.26	4.04	3.67		
Linnes	160	2	72	5.01	5.03	5.02	4.97	4.92	4.83	4.72	4.60	4.44	4.24		



298 <u>Figure 3 Annual electricity produced in the North Wales lagoon under various levels of SLR and plant configurations.</u>

297

296

As with MB, all the curves in Figure 3 show a slight increase in AEP with SLR of 0.2 m to 0.4 m then all start to decline. For the case of 125 x 8 m diameter turbines the loss of AEP becomes significant for SLR exceeding 1.4 m. For the 140 and 160 turbines the AEP loss becomes significant after slightly higher SLR. When SLR reaches 1.6 m to 1.8 m the system struggles to match the pre-SLR low tide levels.

305 Figure 4a shows the sea and impoundment levels for the base case installation with 1.2 m of SLR. The 306 truncated tops of the scenario curves show that pre-SLR high tide limits are easily achieved by simply 307 closing sluices and stopping generation or pumping when the existing high tide level is reached. 308 Pumping is necessary to reach the pre-SLR low tide levels. At neap tides there is little or no difference 309 between the efficient C-by-C operating mode and the FL mode which means there is no cost to reach 310 existing low tide levels. At spring tides, the FL mode starts ebb generation slightly earlier than the C-311 by-C mode and the rate of discharge and turbine speed is slightly greater. The amount of pumping 312 required at low tide is similar, but the FL mode starts earlier. The FL mode achieves the required 313 current MLWS levels with an additional reduction of 1% of the AEP. Spring low tide inside the 314 impoundment lags the natural tide by 2-hours 36-minutes for C-by-C and 2-hours 0-minutes for FL 315 modes.





319 Figure 4 Water levels in the North Wales Coastal Lagoon with 125 x 8 m x 15 MW, 1.2 m sea level rise

320

321 **7 Discussion**

Comparing Figures 1 and 3, it appears that it is easier to maintain pre-SLR levels in the coastal lagoon than the estuarine barrage despite the lagoon having a greater area wetted area at low tide. This result was unexpected and may be due to the specific characteristics of the two sites with a lower tidal range in the lagoon and the higher proportion of flood generation.

The analysis presented by (Vandercruyssen D et al., 2023) assumed there are major plant refits or replacements every 40 years. The LCOE following refits was estimated at 57% of the LCOE for the first 40 years. Thus, there is scope for upgrading the installation and generating more electricity. Options available include: -



Increasing the number of turbines or sluices once the barrage is operational is possible but difficultand would require cofferdams. It is possible to retrofit turbo-generators into dual purpose sluices

- although this saves little money during the initial construction and diminishes the sluicing capacitywhen the additional turbo-generators are installed. A better option may be to increase the diameter
- of the turbines by refitting the draught tube within the turbine caisson. It is assumed that larger
- turbines will be developed as the tidal range industry grows.
- 340 Increasing the pumping power is possible but without specific operating information on the design of 341 low head turbines as pumps the results are currently unpredictable. Installing dedicated pumps may
- 341 low head turbines as pumps the results are currently unpredictable. Installing dedicated pumps may 342 be a better option in situations where the turbines find it difficult to pump to the current low tide
- 343 levels; their efficiency is considerably higher than using turbines as pumps.
- Increasing the initial sluice ratio is also possible but this will be a fine balance between the initial capital
 cost and the additional AEP provided by the sluices.
- Changes in the tidal dynamics of an estuary need detailed and bespoke investigation. However the benefits include not only reduced carbon emissions from sustainable power but also securing supply against power failure. In August 2019, a million people across the UK were plunged into darkness after two National Grid generators spectacularly failed (Molly Rose Pike and Felix Allen, 2019). Large parts of London, the Southeast, Liverpool, Glasgow, Wales, Gloucestershire, and Manchester all lost power. Parts of the railway network could not re-boot, trapping many people on trains for up to 6hours. Ipswich Hospital was also affected when its back-up generator failed to work.

Storm surges will be discussed in a subsequent paper. They make little difference to the AEP as the effects of high or low air pressures usually last longer than a full tide cycle of 12.3-hours. For a lowpressure area, the average sea level will be higher, and winds can increase wave heights. Consequently, there may be slightly more generation on the flood/ebb tide that will be offset by a slight fall in the electricity generated in the following ebb/flood.

358

359 8 Conclusions

During the initial years of SLR after construction, the flood generation will increase slightly due to SLR. Generation during the flood tide will need to stop earlier to limit the maximum sea level but the head at this point will be higher, giving increased efficiency. Conversely, the ebb generation mode will be somewhat less due to the restrictions at high tide and the additional pumping required to reach the low tide levels.

365 For average SLR of up to 0.5 m for the coastal lagoon example and 0.8 m for the estuary example, the 366 impounded water can be kept at pre-SLR levels with no significant reduction in annual generation. As 367 the SLR increases further the AEP falls in both C-by-C and FL operating modes. To safeguard the 368 environment from SLR greater than 1 m, requires increasing the number or size of turbines during 369 planned refits at a future date. It is also possible that design and manufacturing developments over 370 the next 40- or 80-years could utilise the same number of larger and more efficient turbines. The 371 addition of dedicated submersible pumps may be necessary and efficient for the higher ranges of SLR. 372 These will be investigated in a subsequent paper.

373

374 <u>Disclaimer</u>.

The lead author is also a director of North Wales Tidal Energy (NWTE). None of the information

included in this paper is directly from or can be attributed to NWTE.

This research did not receive any specific grant from funding agencies in the public, commercial, or not-for-profit sectors.

379

380 <u>References</u>

- 381Aggidis, G. A. & Benzon, D. S. (2013) Operational optimisation of a tidal barrage across the Mersey382estuaryusing0-Dmodelling.Availableat:383https://www.sciencedirect.com/science/article/abs/pii/S0029801813001352 [66].
- Aggidis, G. A. & Feather, O. (2012) *Tidal range turbines and generation on the Solway Firth*. Available
 at: <u>https://www.sciencedirect.com/science/article/abs/pii/S0960148111006471</u> [Accessed
 23-May-2023 43].
- Baines, J., Newman, V., Hannah, I., Douglas, T., Carlyle, W., Jones, I., Eaton, D., Zeronian, G. & Cegb
 (1983) *DINORWIG PUMPED STORAGE SCHEME. PART 1: DESIGN. PART 2: CONSTRUCTION*.
 Available at: <u>https://doi.org/10.1680/iicep.1983.1360</u>.
- Baker, S. (2021) Development of tidal energy generation modelling using Morecambe Bay as a case
 study under different environmental, storage and demand scenarios.: Lancaster. Available at:
 <u>https://eprints.lancs.ac.uk/id/eprint/151442/1/2020bakermres.pdf</u> [MRes].
- 393 Baker, S., Aggidis, G. & Howard, D. (2023) The Lancaster O-D Tidal Range Model (In preparation).
- Danial Khojasteh, Matthew Lewis, Sasan Tavakoli, Maryam Farzadkhoo, Stefan Felder, Gregorio
 Iglesias & William Glamore (2022) Sea level rise will change estuarine tidal energy: A review.
 Available at: <u>https://doi.org/10.1016/j.rser.2021.111855</u>.
- 397 Decc, Department of Energy and Climate Change, Parsons Brinckerhoff Ltd & Veatch, B. (2008) Interim 398 Options Analysis Report, Vol 1. Available at: 399 https://webarchive.nationalarchives.gov.uk/ukgwa/20101209161505/http://www.decc.gov. 400 uk/publications/basket.aspx?FilePath=What+we+do%2fUK+energy+supply%2fEnergy+mix% 401 2fRenewable+energy%2fSevern+Tidal+Power+feasibility+study%2f1 20090715085042 e % 40%40 OptionsforTidalPowerDevelopmentintheSevernEstuartyAnalysisReportVolume1.pdf 402
- 403 <u>&filetype=4</u>.
 404 Environment Agency & Cumbria County Council (201
- 404Environment Agency & Cumbria County Council (2017) Lyth Valley: Draft Flood Investigation Report,405Flood Event 5th 6th December 2015. Available at:406https://www.cumbria.gov.uk/eLibrary/Content/Internet/544/3887/6729/6735/429891066.p407df.
- 408Harcourt, F., Angeloudis, A. & Piggott, M. D. (2019) Utilising the flexible generation potential of tidal409range power plants to optimise economic value. Available at:410https://www.sciencedirect.com/science/article/pii/S0306261918319093 [237].
- 411Inst of Mech Engs (2019)Rising Seas: The Engineering Challenge.Available at:412https://www.imeche.org/policy-and-press/reports/detail/rising-seas-the-engineering-413challenge [Accessed 11-Jan 2022].
- 414Intergovernmental Panel on Climate Change (Ipcc) (2014)*Climate Change*. Available at:415https://www.ipcc.ch/site/assets/uploads/2018/05/SYR AR5 FINAL full wcover.pdf.
- Laffoley, D., Baxter, J.M., Amon, D.J., Claudet, J., Downs, C.A., Earle, S.A. (2022) *The forgotten ocean: Why COP26 must call for vastly greater ambition and urgency to address ocean change.*:
 Aquatic Conservation: Marine and Freshwater Ecosystems, 32(1), 217–228. Available at:
 <u>https://doi.org/10.1002/aqc.3751</u>.
- Molly Rose Pike & Felix Allen (2019) *Power cut plunges Britain into chaos as thousands stranded on trains in pitch dark for six hours.*: The Sun. Available at: <u>www.thesun.cNational</u> [Accessed 18 Feb 2021].
- Pickering, M. D., Wells, N. C., Horsburgh, K. J. & Green, J. a. M. (2012) *The impact of future sea-level rise on the European Shelf tides*. Available at: <u>https://doi.org/10.1016/j.csr.2011.11.011</u>.

- Vandercruyssen D, Aggidis G. A & Howard D C (2023) *Tidal range generation: combining the Lancaster zero-dimension generation and cost models,* Available at:
 https://doi.org/10.1680/jener.22.00077.
- Vandercruyssen, D., Baker, S., Howard, D. & Aggidis, G. (2022a) *Tidal range electricity generation: A comparison between estuarine barrages and coastal lagoons*. Available at:
 https://doi.org/10.1016/j.heliyon.2022.e11381.
- Vandercruyssen, D., Howard, D. & Aggidis, G. (2022b) A Model of the Costs for Tidal Range Power
 Generation Schemes. Available at: <u>https://doi.org/10.1680/jener.22.00058</u>.
- 433Yates, N., Walkington, I., Burrows, R. & Wolf, J. (2013) The energy gains realisable through pumping434fortidalrangeenergyschemes.Availableat:435https://www.sciencedirect.com/science/article/abs/pii/S0960148113000773[58].